

| | | |
|---|-------------------------------|---------------------------|
| Water System Name: Three Mile Water Distr. | | PWS ID No.: 1110028 RE |
| Collector: Bryon Regehr | Date Collected: 10/17/2013 | County: Boundary |
| Report Results to: Three Mile Water Distr. Bryon Regehr 3635 Moonshadow Bonners Ferry, ID 83805 | | |
| Phone: (208) 267-5166 | | Fax: (208) 267-3351 |
| E-Mail: nancy@youngwithcpa.com, marcia.babcock@deq.idaho.gov | | |

COLIFORM BACTERIA
ANALYSIS REPORT
CONTAMINANT ID# 3100


| | |
|-----------------|-------------------|
| Type of System: | Public |
| Type of Sample: | Compliance Sample |
| Lab Order No.: | 2013100308 |

Water system info must be fully filled out or samples will not be run. Private samples do not need PWS# or Chlorine residual. Your sample will be analyzed for TOTAL COLIFORMS unless you specify analysis under Remarks.

| | |
|---|-------------------------------|
| Laboratory Name: Accurate Testing Labs, LLC 7950 Meadowlark Way Coeur d'Alene, ID 83815 Phone (208) 762 8378 Fax (208) 762 9082 Web site: www.accuratetesting.com E-mail: info@accuratetesting.com | Lab EPA ID No: ID00912 |
|---|-------------------------------|

For PWS only, if this is a repeat sample, mark the date of the ORIGINAL POSITIVE SAMPLE.

| Sample Number | Sample Type | Sample Location | Time Collected | Chlorine Residual ppm | Original Sample Date | Total Coliform Method: 9223B-PA | E. Coli Method: 9223B-PA |
|---------------|----------------------|---------------------------|----------------|-----------------------|----------------------|---------------------------------|--------------------------|
| 145594 | P-Repeat Sample | Office - 266 West Mt View | 07:45 | | | Absent | Absent |
| 145595 | X-Other Repeat | 267 West Mt View | 08:00 | | | Absent | Absent |
| 145596 | W-Untreated (source) | Plant - 266 West Mt View | 07:45 | | | Absent | Absent |

| | | | |
|--|-----------------------------|--------------------------|---------------------------|
| Sample Transportation by (Name): Bryon Regehr | Date/Time: 10/17/2013 11:07 | Analyst: AC | Date Analyzed: 10/18/2013 |
| Sample Received by (Name): JM | Date/Time: 10/17/2013 11:07 | Supervisor: Rhena Cooper | |
| Remarks:  | | | |
| Date Reviewed and Printed: 10/18/13 | | | |

| | | |
|---|-------------------------------|---------------------------|
| Water System Name: Three Mile Water Distr. | | PWS ID No.: 1110028 RE |
| Collector: Bryon Regehr | Date Collected: 10/14/2013 | County: Boundary |
| Report Results to: Three Mile Water Distr. Bryon Regehr 3635 Moonshadow Bonners Ferry, ID 83805 | | |
| Phone: (208) 267-5166 | | Fax: (208) 267-3351 |
| E-Mail: nancy@youngwithcpa.com, marcia.babcock@deq.idaho.gov | | |

COLIFORM BACTERIA
ANALYSIS REPORT
CONTAMINANT ID# 3100

| | |
|-----------------|-------------------|
| Type of System: | Public |
| Type of Sample: | Compliance Sample |
| Lab Order No.: | 2013100261 |

| | |
|---|------------------------|
| Laboratory Name: Accurate Testing Labs, LLC 7950 Meadowlark Way Coeur d'Alene, ID 83815 Phone (208) 762 8378 Fax (208) 762 9082 Web site: www.accuratetesting.com E-mail: info@accuratetesting.com | Lab EPA ID No: ID00912 |
|---|------------------------|

Water system info must be fully filled out or samples will not be run. Private samples do not need PWS# or Chlorine residual. Your sample will be analyzed for TOTAL COLIFORMS unless you specify analysis under Remarks.

For PWS only, if this is a repeat sample, mark the date of the ORIGINAL POSITIVE SAMPLE.

| Sample Number | Sample Type | Sample Location | Time Collected | Chlorine Residual ppm | Original Sample Date | Total Coliform Method: 9223B-PA | E. Coli Method: 9223B-PA |
|---------------|-------------------|---------------------|----------------|-----------------------|----------------------|---------------------------------|--------------------------|
| 145478 | RS-Routine Sample | 3635 Moonshadow Rd | 07:50 | | | Absent | Absent |
| 145479 | RS-Routine Sample | 266 West Mt View Rd | 10:20 | | | Present | Absent |

| | | | | | | | |
|----------------------------------|-------------------------------------|------------|------------------|-------------|--------------|----------------|------------|
| Sample Transportation by (Name): | Bryon Regehr | Date/Time: | 10/15/2013 11:30 | Analyst: | AC | Date Analyzed: | 10/16/2013 |
| Sample Received by (Name): | JM | Date/Time: | 10/15/2013 11:30 | Supervisor: | Rhena Cooper | | |
| Remarks: | Date Reviewed and Printed: 10/16/13 | | | | | | |

Accurate Testing Labs, LLC

7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378 Fax (208) 762 9082

Certificate of Analysis

Order No.: **2013100261**

Page: 1 of 1

Bryon Regehr
Three Mile Water Distr.
3635 Moonshadow
Bonners Ferry, ID 83805

Description: Three Mile Water
Date Received: 10/15/2013 11:30

Sample: **3**
Location: North Well # 5
Sample Type: Plant Tap

Matrix: Drinking Water
D/T Collected: 10/14/2013 10:45
Collected by: Bryon Regehr

| Analyte | Result | Unit | Method | PQL | Analysis Date | Analyst |
|----------------------------|--------|------|-----------|-------|---------------|---------|
| Calcium | 60.8 | mg/L | EPA 200.7 | 0.17 | 10/17/13 | WM |
| Hardness, Total (as CaCO3) | 11.4 | GPG | SM 2340 | 0.02 | 10/17/13 | WM |
| Iron | 0.025 | mg/L | EPA 200.7 | 0.015 | 10/17/13 | WM |
| Magnesium | 10.5 | mg/L | EPA 200.7 | 0.03 | 10/17/13 | WM |
| Manganese | ND | mg/L | EPA 200.7 | 0.01 | 10/17/13 | WM |
| pH | 7.07 | | EPA 150.1 | | 10/15/13 | AC |

Water quality parameters:

pH: Normal range: 6.5 - 8.5

Iron: Maximum contaminants level: 0.3 mg/L
Sources: Naturally occurring, corrosion of pipe
Adverse effects: Objectionable taste and odor, discolors laundry and fixtures

Manganese: Maximum contaminants level: 0.05 mg/L
Sources: Naturally occurring
Adverse effects: Objectionable taste and odor, discolors laundry and fixtures

Hardness: 1 - 3.5 slightly hard 7.0 -10.5 hard
3.5 - 7.0 moderately hard 10.5 - over very hard



Laboratory Supervisor, Walter Mueller Date: 10/17/13



ND: Not Detected PQL: Practical Quantitation Limit
www.accuratetesting.com info@accuratetesting.com

Accurate Testing Labs, LLC

7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378 Fax (208) 762 9082

Certificate of Analysis

Order No.: 2013100261

Page: 1 of 1

Bryon Regehr
Three Mile Water Distr.
3635 Moonshadow
Bonners Ferry, ID 83805

Description: Three Mile Water
Date Received: 10/15/2013 11:30

Sample: 4
Location: North Well # 4
Sample Type: Plant Tap

Matrix: Drinking Water
D/T Collected: 10/14/2013 10:45
Collected by: Bryon Regehr

| Analyte | Result | Unit | Method | PQL | Analysis Date | Analyst |
|----------------------------|--------|------|-----------|-------|---------------|---------|
| Calcium | 78.9 | mg/L | EPA 200.7 | 0.17 | 10/17/13 | WM |
| Hardness, Total (as CaCO3) | 14.9 | GPG | SM 2340 | 0.02 | 10/17/13 | WM |
| Iron | 0.017 | mg/L | EPA 200.7 | 0.015 | 10/17/13 | WM |
| Magnesium | 14.0 | mg/L | EPA 200.7 | 0.03 | 10/17/13 | WM |
| Manganese | ND | mg/L | EPA 200.7 | 0.01 | 10/17/13 | WM |
| pH | 7.02 | | EPA 150.1 | | 10/15/13 | AC |

Water quality parameters:

pH: Normal range: 6.5 - 8.5

Iron: Maximum contaminants level: 0.3 mg/L
Sources: Naturally occurring, corrosion of pipe
Adverse effects: Objectionable taste and odor, discolors laundry and fixtures

Manganese: Maximum contaminants level: 0.05 mg/L
Sources: Naturally occurring
Adverse effects: Objectionable taste and odor, discolors laundry and fixtures

Hardness: 1 - 3.5 slightly hard 7.0 -10.5 hard
3.5 - 7.0 moderately hard 10.5 - over very hard



Laboratory Supervisor, Walter Mueller Date: 10/17/13



ND: Not Detected PQL: Practical Quantitation Limit
www.accuratetesting.com info@accuratetesting.com