

Lab EPA ID No: ID00912	Supervisor: Walter Mueller
Date Received: 06/13/2014	Date Reported: 06/20/2014
Sample Purpose: Compliance	
Sample Type: Distribution	
PWS No: <b>1110028 RE</b>	PWS Name: <b>Three Mile Water</b>
County: Boundary	

Laboratory Name:  
**Accurate Testing Labs, LLC**  
7950 Meadowlark Way  
Coeur d'Alene, ID 83815  
Phone (208) 762 8378  
Fax (208) 762 9082  
Web site: www.accuratetesting.com  
E-mail: info@accuratetesting.com

**Order Number: 2014060258**

**INORGANIC CHEMICALS(IOC's) REPORT FOR LEAD & COPPER**

		<b>Copper</b>	<b>Lead</b>	
Action Level (AL):		1.3 mg/L	0.015 mg/l	
Test Method:		EPA 200.5	EPA 200.5	
Analyst:		WM	WM	
<b>Lab Sample #</b>	<b>Date Collected</b>	<b>Sampling Location</b>	<b>Copper mg/L</b>	<b>Lead mg/L</b>
151447	06/13/2014	Bryon Regehr M-20	0.957	0.0014
151448	06/13/2014	Leah Johnson M-742	0.0522	0.0014
151449	06/13/2014	Greg Dirks NB-19	0.601	0.0012
151450	06/13/2014	Stacy Van Alstyne M-213	0.354	0.0018
151451	06/13/2014	Ken Brink 266 West Mtn View	0.0562	0.0017
151452	06/13/2014	Gary Jones NB36	0.570	0.0010
151453	06/13/2014	John Tice M167	0.256	0.0015
151454	06/13/2014	Randell Hoch SB2	0.319	0.0026
151455	06/13/2014	Karla Winger M477	1.06	ND
151456	06/13/2014	Brett Payne M186	0.466	0.0012

Three Mile Water Distr.

3635 Moonshadow  
Bonners Ferry, ID 83805



Laboratory Supervisor Walter Mueller

06/20/14