

Lab EPA ID No: ID00912	Supervisor: Walter Mueller
Date Received: 06/02/2015	Date Reported: 06/04/2015
Sample Purpose: Compliance	
Sample Type: Distribution	
PWS No: 1110028 RE	PWS Name: Three Mile Water Dist
County: Boundary	

Laboratory Name:
Accurate Testing Labs, LLC
7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378
Fax (208) 762 9082
Web site: www.accuratetesting.com
E-mail: info@accuratetesting.com

Order Number: 2015060074

INORGANIC CHEMICALS(IOC's) REPORT FOR LEAD & COPPER

	Copper	Lead
Action Level (AL):	1.3 mg/L	0.015 mg/l
Test Method:	EPA 200.5	EPA 200.5
Analyst:	WM	WM

Lab Sample #	Date Collected	Sampling Location	Copper mg/L	Lead mg/L
161443	06/02/2015	Bryon Regehr M-20	0.767	0.0015
161444	06/02/2015	Leah Johnson M-742	0.0845	0.0027
161445	06/02/2015	Greg Dirks NB-19	0.793	0.0021
161446	06/02/2015	Stacy VanAlstyne M-213	0.323	0.0018
161447	06/02/2015	Ken Brink M-14	0.435	0.0031
161448	06/02/2015	Chad Argon NB-36	0.433	0.0019
161449	06/02/2015	John Tice M-167	0.460	0.0023
161450	06/02/2015	Randall Hoch SB-2	0.456	0.0030
161451	06/02/2015	Karla Winger M-477	1.01	0.0020
161452	06/02/2015	Brett Payne M-186	0.796	0.0017

Three Mile Water Distr.

3635 Moonshadow
Bonners Ferry, ID 83805



06/04/15

Laboratory Supervisor, Digitally signed by: *Walter*