

Lab EPA ID No: ID00912	Supervisor: Walter Mueller
Date Received: 06/11/2013	Date Reported: 06/19/2013
Sample Purpose: Compliance	
Sample Type: Distribution	
PWS No: 1110028 RE	PWS Name: Three Mile Water
County: Boundary	

Laboratory Name:
Accurate Testing Labs, LLC
7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378
Fax (208) 762 9082
Web site: www.accuratetesting.com
E-mail: info@accuratetesting.com


Order Number: 2013060215

INORGANIC CHEMICALS(IOC's) REPORT FOR LEAD & COPPER

		Copper	Lead	
Action Level (AL):		1.3 mg/L	0.015 mg/l	
Test Method:		EPA 200.5	EPA 200.5	
Analyst:		WM	WM	
Lab Sample #	Date Collected	Sampling Location	Copper mg/L	Lead mg/L
140944	06/11/2013	Ken Brink NB14	0.392	0.0026
140945	06/11/2013	Bryon Regehr M20	0.788	0.0016
140946	06/11/2013	Brett Payne M186	0.255	ND
140947	06/11/2013	Leah Johnson M742	0.0815	0.0017
140948	06/11/2013	Greg Dirks NB19	0.370	0.0014
140949	06/11/2013	Gary Jones NB36	0.107	0.0016
140950	06/11/2013	Gary Woods SB2	0.0902	0.0016
140951	06/11/2013	Karla Wenger M477	0.816	0.0027
140952	06/11/2013	Stacy Van Alstyne M213	0.585	0.0017
140953	06/11/2013	John Tice M167	0.561	0.0024

Three Mile Water Distr.

3635 Moonshadow
Bonners Ferry , ID 83805


Laboratory Supervisor Walter Mueller

06/19/13 