

**Accurate Testing Labs, LLC**

7950 Meadowlark Way  
Coeur d'Alene, ID 83815  
Phone (208) 762 8378 Fax (208) 762 9082

**STATE OF IDAHO**  
**Drinking Water Coliform Bacteria Analysis**  
**Report**

Order No.: 2013070158 1

Report Date: 07/11/13

Three Mile Water Distr.  
3635 Moonshadow  
Bonners Ferry , ID 83805

Water System: Private Well  
Location: 744 Grouse Hill Rd  
County: Boundary  
Collected by: Schneider  
Sample Type: C-Construction

Date Collected: 07/08/2013  
Time Collected: 07:00

Date Received: 07/09/2013  
Time Received: 14:30

Method	Analyte	Result	Analysis Date	Analyst
9223B-PA	E. Coli	Absent	07/10/13	JR
9223B-PA	Total Coliform	Absent	07/10/13	JR

**Notes:**

IF YOUR RESULT IS "ABSENT": The absence of coliform bacteria indicates that your water is not contaminated with coliform bacteria.

IF YOUR RESULT IS "PRESENT": The presents of coliform bacteria means that your water is contaminated, and may contain disease causing organisms. Contaminated water should not be used for drinking water.

If coliform bacteria are present, an additional test has been run for Escherichia coli bacteria. The result for this test is also reported as being present or absent.

# Accurate Testing Labs, LLC

7950 Meadowlark Way  
Coeur d'Alene, ID 83815  
Phone (208) 762 8378 Fax (208) 762 9082

# Certificate of Analysis

Order No.: 2013070158

Page: 1 of 1

Bryon Regehr  
Three Mile Water Distr.  
3635 Moonshadow  
Bonners Ferry, ID 83805

Description: Private Well  
Date Received: 07/09/2013 14:30

Sample: 2  
Location: 744 Grouse Hill Rd  
Sample Type: C-Construction

Matrix: Drinking Water  
D/T Collected: 07/08/2013 07:00  
Collected by: Schneider

Analyte	Result	Unit	Method	PQL	Analysis Date	Analyst
Calcium	125	mg/L	EPA 200.7	0.17	07/11/13	WM
Hardness, Total (as CaCO3)	22.8	GPG	SM 2340	0.02	07/11/13	WM
Iron	1.09	mg/L	EPA 200.7	0.015	07/11/13	WM
Magnesium	18.7	mg/L	EPA 200.7	0.03	07/11/13	WM
Manganese	0.224	mg/L	EPA 200.7	0.01	07/11/13	WM
pH	7.06		EPA 150.1		07/10/13	AC

### Water quality parameters:

pH: Normal range: 6.5 - 8.5

Iron: Maximum contaminants level: 0.3 mg/L  
Sources: Naturally occurring, corrosion of pipe  
Adverse effects: Objectionable taste and odor, discolors laundry and fixtures

Manganese: Maximum contaminants level: 0.05 mg/L  
Sources: Naturally occurring  
Adverse effects: Objectionable taste and odor, discolors laundry and fixtures

Hardness: 1 - 3.5 slightly hard 7.0 -10.5 hard  
3.5 - 7.0 moderately hard 10.5 - over very hard



Laboratory Supervisor, Walter Mueller Date: 07/11/13



ND: Not Detected PQL: Practical Quantitation Limit  
www.accuratetesting.com info@accuratetesting.com