

Lab EPA ID No.: ID00912	Lab Sample#: 211683
Date Received: 12/06/2019	Date Reported by Lab: 12/19/19
Compliance or Replacement Sample: Compliance	
Date Collected: 12/05/2019	Time Collected: 15:30
Sample Type: Plant Tap	
PWS No.: 1110028 RE	PWS Name: Three Mile Water Distr.
Sampling Location: Canyon River Wellfield	Tag#
Collector: Dustin Ridgley	Phone: (208) 304-5627

Laboratory Name:  
**Accurate Testing Labs, LLC**  
7950 Meadowlark Way  
Coeur d'Alene, ID 83815  
Phone (208) 762 8378  
Fax (208) 762 9082  
Web site: www.accuratetesting.com  
E-mail: info@accuratetesting.com


**Lab Order No.: 2019120167 1**

**Public Drinking Water System INORGANIC CHEMICAL (IOC) ANALYSIS REPORT:**

Phase II								Phase V							
FRDS	Analytes	Results	MCL*	MDL*	Method	Analysis Date	Analyst	FRDS	Analytes	Results	MCL*	MDL*	Method	Analysis Date	Analyst
1010	Barium	ND	2.0	0.02	EPA 200.7	12/09/19	WM	1036	Nickel	ND	0.10	0.005	EPA 200.7	12/09/19	WM
1015	Cadmium	ND	0.001	0.001	EPA 200.7	12/09/19	WM	1074	Antimony	ND	0.006	0.003	EPA 200.9	12/17/19	WM
1020	Chromium	ND	0.10	0.007	EPA 200.7	12/09/19	WM	1075	Beryllium	ND	0.004	0.000	EPA 200.7	12/09/19	WM
1035	Mercury	ND	0.002	0.000	EPA 245.1	12/09/19	WM	1085	Thallium	ND	0.002	0.001	EPA 200.9	12/16/19	WM
1038	NO2/NO3	ND	10.0	0.1	EPA 300.0	12/07/19	WM	<i>Other IOCs</i>							
1040	Nitrate-N	ND	10.0	0.1	EPA 300.0	12/06/19	WM	1005	Arsenic	ND	0.010	0.001	EPA 200.9	12/10/19	WM
1041	Nitrite-N	ND	1	0.1	EPA 300.0	12/06/19	WM	1025	Fluoride	ND	4.0	0.1	EPA 300.0	12/06/19	WM
1045	Selenium	ND	0.050	0.002	EPA 200.9	12/18/19	WM	1052	Sodium	2.93	500	0.3	EPA 200.7	12/19/19	WM
1024	Cyanide														
<i>Secondary IOCs (optional)</i>															
1002	Aluminum							1055	Sulfate	3.34	250	0.3	EPA 300.0	12/06/19	WM
1003	Ammonia							1095	Zinc						
1016	Calcium							1905	Color						
1017	Chloride							1915	Hardness						
1022	Copper							1920	Odor						
1027	Hyd. Sulfide							1925	pH						
1028	Iron							1926	Conductivity						
1031	Magnesium							1927	Alkalinity						
1032	Manganese							1930	Diss. Solids						
1042	Postassium							1997	Langlier Indx						
1049	Silica SiO2							2905	Surfactants						
1050	Silver							1030	Lead						

\*Reported in mg/L unless otherwise noted, units differ for secondary MCLs depending on contaminant  
ND = Not detected within sensitivity of instrument  
Empty = No analysis performed for this contaminant  
MDL = Method detection limit  
MCL - Maximum Contaminant Level

Comments:



12/19/19

Three Mile Water Distr.  
3635 Moonshadow  
Bonners Ferry, ID 83805

Laboratory  
Supervisor,  
Digitally signed by:  
Walter Mueller

Lab EPA ID No.: ID00912	Lab Sample#: 211684
Date Received: 12/06/2019	Date Reported by Lab: 12/19/19
Compliance or Replacement Sample: Compliance	
Date Collected: 12/05/2019	Time Collected: 14:00
Sample Type: Plant Tap	
PWS No.: 1110028 RE	PWS Name: Three Mile Water Distr.
Sampling Location: North Hops Wellfield 1,2,3,4	Tag#
Collector: Dustin Ridgley	Phone: (208) 304-5627

Laboratory Name:  
**Accurate Testing Labs, LLC**  
 7950 Meadowlark Way  
 Coeur d'Alene, ID 83815  
 Phone (208) 762 8378  
 Fax (208) 762 9082  
 Web site: www accuratetesting.com  
 E-mail: info@accuratetesting.com


**Lab Order No.: 2019120167 2**

**Public Drinking Water System INORGANIC CHEMICAL (IOC) ANALYSIS REPORT:**

Phase II								Phase V							
FRDS	Analytes	Results	MCL*	MDL*	Method	Analysis Date	Analyst	FRDS	Analytes	Results	MCL*	MDL*	Method	Analysis Date	Analyst
1010	Barium	ND	2.0	0.02	EPA 200.7	12/09/19	WM	1036	Nickel	ND	0.10	0.005	EPA 200.7	12/09/19	WM
1015	Cadmium	ND	0.001	0.001	EPA 200.7	12/09/19	WM	1074	Antimony	ND	0.006	0.003	EPA 200.9	12/17/19	WM
1020	Chromium	ND	0.10	0.007	EPA 200.7	12/09/19	WM	1075	Beryllium	ND	0.004	0.000	EPA 200.7	12/09/19	WM
1035	Mercury	ND	0.002	0.000	EPA 245.1	12/09/19	WM	1085	Thallium	ND	0.002	0.001	EPA 200.9	12/16/19	WM
1038	NO2/NO3	1.25	10.0	0.1	EPA 300.0	12/07/19	WM	<i>Other IOCs</i>							
1040	Nitrate-N	1.25	10.0	0.1	EPA 300.0	12/06/19	WM	1005	Arsenic	ND	0.010	0.001	EPA 200.9	12/10/19	WM
1041	Nitrite-N	ND	1	0.1	EPA 300.0	12/06/19	WM	1025	Fluoride	0.130	4.0	0.1	EPA 300.0	12/06/19	WM
1045	Selenium	ND	0.050	0.002	EPA 200.9	12/18/19	WM	1052	Sodium	8.96	500	0.3	EPA 200.7	12/19/19	WM
1024	Cyanide														
<i>Secondary IOCs (optional)</i>															
1002	Aluminum							1055	Sulfate	18.4	250	0.3	EPA 300.0	12/06/19	WM
1003	Ammonia							1095	Zinc						
1016	Calcium							1905	Color						
1017	Chloride							1915	Hardness						
1022	Copper							1920	Odor						
1027	Hyd. Sulfide							1925	pH						
1028	Iron							1926	Conductivity						
1031	Magnesium							1927	Alkalinity						
1032	Manganese							1930	Diss. Solids						
1042	Postassium							1997	Langlier Indx						
1049	Silica SiO2							2905	Surfactants						
1050	Silver							1030	Lead						

\*Reported in mg/L unless otherwise noted, units differ for secondary MCLs depending on contaminant  
 ND = Not detected within sensitivity of instrument  
 Empty = No analysis performed for this contaminant  
 MDL = Method detection limit  
 MCL - Maximum Contaminant Level

Comments:



12/19/19

Three Mile Water Distr.  
 3635 Moonshadow  
 Bonners Ferry, ID 83805

Laboratory  
 Supervisor,  
 Digitally signed by:  
 Walter Mueller