

Lab EPA ID No.: ID00912	Lab Sample#: 211687
Date Received: 12/06/2019	Date Reported by Lab: 12/26/19
Compliance or Replacement Sample: Compliance	
Date Collected: 12/05/2019	Time Collected: 15:12
Sample Type: Plant Tap	
PWS No.: 1110028 RE	PWS Name: Three Mile Water Distr.
Sample Location: Canyon River Wellfield	
Collector: Dustin Ridgley	Phone: (208) 304-5627

Laboratory Name:
Accurate Testing Labs, LLC
7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378 Fax (208) 762 9082
Web site: www.accuratetesting.com
E-mail: info@accuratetesting.com

Lab Order No.: **2019120169** **1**


Public Drinking Water System VOLATILE ORGANIC (VOC) ANALYSIS REPORT:

Method:	EPA 524.3	Analyst:	ANA		Analysis Date:		12/17/19		
FRDS	Contaminant	Results*	MCL*	MDL*	FRDS	Contaminant	Results*	MCL*	MDL*
2378	1,2,4-Trichlorobenzene	ND	70.0	0.5	2979	trans-1,2-Dichloroethylene	ND	100.0	0.5
2380	cis-1,2-Dichloroethylene	ND	70.0	0.5	2980	1,2-Dichloroethane	ND	5.0	0.5
2950	Trihalomethanes-Total	ND	80	0.5	2981	1,1,1-Trichloroethane	ND	200	0.5
2943	Bromodichloromethane	ND		0.5	2982	Carbon Tetrachloride	ND	5.0	0.5
2942	Bromoform	ND		0.5	2983	1,2-Dichloropropane	ND	5.0	0.5
2941	Chloroform	ND		0.5	2984	Trichloroethylene	ND	5.0	0.5
2944	Dibromochloromethane	ND		0.5	2985	1,1,2-Trichloroethane	ND	5.0	0.5
2955	Xylenes-Total	ND	10000	0.5	2987	Tetrachloroethylene	ND	5.0	0.5
2964	Dichloromethane	ND	5.0	0.5	2989	Monochlorobenzene	ND	100	0.5
2968	o-Dichlorobenzene	ND	600	0.5	2990	Benzene	ND	5.0	0.5
2969	p(1,4)-Dichlorobenzene	ND	75.0	0.5	2991	Toluene	ND	1000	0.5
2976	Vinyl Chloride	ND	2.0	0.5	2992	Ethylbenzene	ND	700	0.5
2977	1,1-Dichloroethylene	ND	7.0	0.5	2996	Styrene	ND	100	0.5

*Reported in ug/L unless otherwise noted, units differ for secondary MCLs depending on contaminant
ND = Not detected within sensitivity of instrument
Empty = No analysis performed for this contaminant
MDL = Method detection limit
MCL - Maximum Contaminant Level
VOC: Sub_Lab: Anatek Labs, Inc.

Comments:

Three Mile Water Distr.
3635 Moonshadow
Bonners Ferry, ID 83805



Laboratory Supervisor
Digitally signed by:
Walter Mueller

12/26/19

Lab EPA ID No.: ID00912	Lab Sample#: 211688
Date Received: 12/06/2019	Date Reported by Lab: 12/26/19
Compliance or Replacement Sample: Compliance	
Date Collected: 12/05/2019	Time Collected: 14:12
Sample Type: Plant Tap	
PWS No.: 1110028 RE	PWS Name: Three Mile Water Distr.
Sample Location: North Hops Wellfield 1,2,3,4	
Collector: Dustin Ridgley	Phone: (208) 304-5627

Laboratory Name:
Accurate Testing Labs, LLC
7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378 Fax (208) 762 9082
Web site: www.accuratetesting.com
E-mail: info@accuratetesting.com

Lab Order No.: 2019120169 2


Public Drinking Water System VOLATILE ORGANIC (VOC) ANALYSIS REPORT:

Method: EPA 524.3		Analyst: ANA			Analysis Date: 12/17/19				
FRDS	Contaminant	Results*	MCL*	MDL*	FRDS	Contaminant	Results*	MCL*	MDL*
2378	1,2,4-Trichlorobenzene	ND	70.0	0.5	2979	trans-1,2-Dichloroethylene	ND	100.0	0.5
2380	cis-1,2-Dichloroethylene	ND	70.0	0.5	2980	1,2-Dichloroethane	ND	5.0	0.5
2950	Trihalomethanes-Total	ND	80	0.5	2981	1,1,1-Trichloroethane	ND	200	0.5
2943	Bromodichloromethane	ND		0.5	2982	Carbon Tetrachloride	ND	5.0	0.5
2942	Bromoform	ND		0.5	2983	1,2-Dichloropropane	ND	5.0	0.5
2941	Chloroform	ND		0.5	2984	Trichloroethylene	ND	5.0	0.5
2944	Dibromochloromethane	ND		0.5	2985	1,1,2-Trichloroethane	ND	5.0	0.5
2955	Xylenes-Total	ND	10000	0.5	2987	Tetrachloroethylene	ND	5.0	0.5
2964	Dichloromethane	ND	5.0	0.5	2989	Monochlorobenzene	ND	100	0.5
2968	o-Dichlorobenzene	ND	600	0.5	2990	Benzene	ND	5.0	0.5
2969	p(1,4)-Dichlorobenzene	ND	75.0	0.5	2991	Toluene	ND	1000	0.5
2976	Vinyl Chloride	ND	2.0	0.5	2992	Ethylbenzene	ND	700	0.5
2977	1,1-Dichloroethylene	ND	7.0	0.5	2996	Styrene	ND	100	0.5

*Reported in ug/L unless otherwise noted, units differ for secondary MCLs depending on contaminant
ND = Not detected within sensitivity of instrument
Empty = No analysis performed for this contaminant
MDL = Method detection limit
MCL - Maximum Contaminant Level
VOC: Sub_Lab: Anatek Labs, Inc.

Comments:

Three Mile Water Distr.
3635 Moonshadow
Bonners Ferry, ID 83805



Laboratory Supervisor
Digitally signed by:
Walter Mueller

12/26/19