

Lab EPA ID No: ID00912	Supervisor: Walter Mueller
Date Received: 09/26/2022	Date Reported: 10/16/2022
Sample Purpose: Compliance	
Sample Type: Distribution	
PWS No: 1110028 RE	PWS Name: Three Mile Water
County: Boundary	

Laboratory Name:
Accurate Testing Labs, LLC
7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378
Fax (208) 762 9082
Web site: www.accuratetesting.com
E-mail: info@accuratetesting.com

Order Number: 2022090785

INORGANIC CHEMICALS(IOC's) REPORT FOR LEAD & COPPER

		Copper	Lead	
Action Level (AL):		1.3 mg/L	0.015 mg/l	
Test Method:		EPA 200.5	EPA 200.5	
Analyst:		WM	WM	
Lab Sample #	Date Collected	Sampling Location	Copper mg/L	Lead mg/L
247333	09/23/2022	NB27	2.18	0.0029
247334	09/21/2022	SB4	0.594	0.0032
247335	09/22/2022	M23	0.218	ND
247336	09/22/2022	M190	0.138	0.0018
247337	09/22/2022	M193	0.524	0.0018
247338	09/22/2022	M368	1.26	0.0012
247339	09/23/2022	M144	0.874	0.0014
247340	09/21/2022	M405	0.610	ND
247341	09/21/2022	SB6	0.287	0.0041
247342	09/21/2022	M20	0.817	ND

Three Mile Water Distr.

3635 Moonshadow
Bonners Ferry, ID 83805



10/16/22

Laboratory Supervisor, Digitally signed by: *Walter*