

Lab EPA ID No.: ID00912	Lab Sample#: 248105
Date Received: 10/10/2022	Date Reported by Lab: 01/26/23
Compliance or Replacement Sample: Compliance	
Date Collected: 10/10/2022	Time Collected: 11:10
Sample Type: Plant Tap	
PWS No.: 1110028 RE	PWS Name: Three Mile Water Distr.
Sample Location: North Wellfield	
Collector: Dustin Ridgley	Phone: (208) 304-5627

Laboratory Name: Accurate Testing Labs, LLC 7950 Meadowlark Way Coeur d'Alene, ID 83815 Phone (208) 762 8378 Fax (208) 762 9082 Web site: www.accuratetesting.com E-mail: info@accuratetesting.com

Lab Order No.:	2022100196	1
----------------	-------------------	----------

Public Drinking Water System RADIOLOGICAL ANALYSIS REPORT:

FRDS	Contaminant	Results	Units	MCL	MDL	Analysis Date	Analyst	Method
4020	Radium 226	<0.160+/-0.085	pCi/L	5	1	01/20/23	SUB	EPA 903.0
4030	Radium 228	<0.203+/-0.427	pCi/L	5	1	01/17/23	SUB	EPA 904.0

ND = Not detected within sensitivity of instrument
Empty = No analysis performed for this contaminant
MDL = Method detection limit
MCL - Maximum Contaminant Level
Sub_Lab: Anatek Labs

Sub Lab: Anatek

Three Mile Water Distr.
Bryon Regehr
3635 Moonshadow
Bonners Ferry, ID 83805



01/26/23

Laboratory Supervisor, Digitally signed by: *Walter*