

Lab EPA ID No: ID00912	Supervisor: Walter Mueller
Date Received: 10/06/2025	Date Reported: 10/19/2025
Sample Purpose: Compliance	
Sample Type: Distribution	
PWS No: 1110028 RE	PWS Name: Three Mile Water
County: Boundary	

Laboratory Name:
Accurate Testing Labs, LLC
7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378
Fax (208) 762 9082
Web site: www accuratetesting.com
E-mail: info@accuratetesting.com

Order Number: 2025100102

INORGANIC CHEMICALS(IOC's) REPORT FOR LEAD & COPPER

	Copper	Lead
Action Level (AL):	1.3 mg/L	0.015 mg/l
Test Method:	EPA 200.5	EPA 200.5
Analyst:	WM	WM

Lab Sample #	Date Collected	Sampling Location	Copper mg/L	Lead mg/L
288940	10/04/2025	M23	0.735	ND
288941	10/03/2025	SB6	0.322	0.0030
288942	10/06/2025	SB4	0.188	0.0057
288943	10/04/2025	NB27	0.811	0.0010
288944	10/03/2025	NB78	0.150	ND
288945	10/06/2025	M144	0.781	0.024
288946	10/03/2025	M405	0.368	ND
288947	10/03/2025	M190	0.176	0.011
288948	10/03/2025	M193	0.116	0.0009
288949	10/06/2025	M20	0.565	0.0032

Three Mile Water Distr.

3635 Moonshadow
Bonners Ferry, ID 83805



10/19/25

Laboratory Supervisor, Digitally signed by: *Walter*